

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:167 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 6297(*)-200 remote transponder with relay, 6297(*)-R200 remote transponder w/o relay, 6297(*)-201 contact transponder, 6298(*)-R201 output zone module, 6299(*)-100 line fault isolator. Refer to listee's data sheet for detailed product description and operational considerations.

(*): alpha character between A and Z except C.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed Model ESA2000 control unit (CSFM Listing No. 7165-1591:144 and 7170-1591:113).

NOTE: Formerly 7300-1388:182

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager